




## Upgrading the Firmware


1. Connect the CONV4USB or the 307USB to the "Serial" or "Upgrade" port of the module or panel as shown on the connection diagrams.



2. Start WinLoad and click on the In-Field Firmware Programmer button.



*If your control panel is not automatically detected, click the **Com port settings** button and select the correct Com port. Then, click the **Refresh Product Info** button to connect with the panel.*



3. Verify the **product information** located in the window.

4. In the drop down menu, select the most recent version of the firmware.

5. Use this button to load additional firmware files from another location or click **Download firmware from the web** to get the latest firmware online.

6. Click on **Update product firmware**.





*If the upgrade process is not completed properly, either because Cancel was pressed or because of technical problems, the panel or module will not function until a firmware is properly transferred.*

# Upgrading Control Panels and Magellan Modules

CONV4USB

307USB



# Upgrading EVO641/ EVO641R Keypads

